

# **INSTRUCTIONS MANUAL**

Congratulation, you have just purchased a C.E.T. skid mounted pump. If you follow the procedures in this operation manual, it will give you years of use without any problems.

### ENGINE SPECIFICATIONS

- D902 Kubota liquid cooled engine.
- 3-cylinder diesel engine
- Electric start.
- Alternator capacity: 12V-40A (480W)

# PUMP UNIT SPECIFICATIONS

- C.E.T. single stage centrifugal pump.
- Pump body made from high resistant aluminum alloy.
- Bronze impellers.
- Mechanical shaft seal.
- Stainless steel pump shaft.
- Electric priming system, guaranteed up to 20' (6 meter) lift.
- One 1 <sup>1</sup>/<sub>2</sub>" (38 mm) delivery outlet.
- One 2 <sup>1</sup>/<sub>2</sub> " (65 mm) suction inlet.
- Dimensions: Length: 29-1/2'' (750 mm); Width: 26'' (660 mm); Height: 33'' (838 mm)
- Wet weight: 308 lbs (140 kg)

# CONTROL PANEL

- Engine start/stop switch.
- Throttle control lever.
- Operating panel light.
- Pilot lights.
- Pressure gauge.
- Vacuum pressure gauge.
- Priming button

### PERFORMANCE

MAX FLOW: 320 GPM 315 GPM (1192 LPM) @ 10 PSI (0.68 BAR) 300 GPM (983 LPM) @ 50 PSI (3.45 BAR) 230 GPM (870 LPM) @ 100 PSI (6.89 BAR) 145 GPM (549 LPM) @ 150 PSI (10.34 BAR) 105 GPM (397 LPM) @ 175 PSI (12.07 BAR) MAX PRESSURE: 185 PSI

Your pump comes with a full year warranty on all mechanical components.



ACCEPT ONLY THE BEST 75 Hector St., P.O. Box 90, Pierreville (Québec) Canada JOG 1J0 Telephone: 1-800-567-2719 Fax: 1-800-434-2613 www.fire-pump.com

A CENTURY OF ENGINEERING FOR THE BRAVEST

# **INSTRUCTIONS MANUAL**

# DOS AND DONTS

#### Do...

- Read your Kubota D902 owner's manual
- Close your drain valve on the pump casing before starting the engine
- Seal up any air that could leak into the suction side
- Charge you battery at least once every three months
- Stop your pump before fuelling

#### Do Not...

- Let your pump freeze up with water in it (drain the casing)
- Allow sand in the suction it will damage the wear ring and the mechanical seal (use floating strainer if water supply doubtful)
- Run your pump dry for more than 2 minutes at idle (prime as soon as possible)
- Use your pump with less than 12 in of water below the inlet of the suction hose
- Allow your pump to run without surveillance
- Run the pump with the discharge valve closed for more than 1 minute

### STARTING PROCEDURE

- Place your pump on a hard, stable surface within 15° from horizontal.
- Check the oil and the fuel tank level.
- Connect your suction hose. Make sure that there is a rubber seal on the adapter and screw it tight.
- Close all the discharge valves.
- Close the drain valve (below the casing of the pump).
- Turn key to ON position. The "glow plugs" light comes on indicating glow plugs are preheating combustion chamber.
- Start the engine and let it idle.
- When "glow plugs" light goes out, turn key to "Ignition" (IG).
- Open the primer ball valve.
- Close this ball valve only when you have pressure on the suction.
- Push the priming button.
- When water comes out of the priming pump (it should take approximately 10 to 15 sec. with a 10 ft x 4" suction hose), release the electric priming button. Do not operate the primer more than 20 sec.
- Open the discharge valve to allow water to run through the pump
- Adjust the RPM with the throttle to desired pressure.

#### N.B. 1 The exhaust system is very hot. Do not touch

N.B. 2 When you are done with the pump, always drain the pump casing



ACCEPT ONLY THE BEST 75 Hector St., P.O. Box 90, Pierreville (Québec) Canada JOG 1J0 Telephone: 1-800-567-2719 Fax: 1-800-434-2613 www.fire-pump.com

A CENTURY OF ENGINEERING FOR THE BRAVEST

### SM-PFP-25hp-DSL-MR

# **INSTRUCTIONS MANUAL**

### TROUBLESHOOTING

Before calling us, try the following if your pump does not operate properly.

#### If the electric primer does not work properly.

- Check the casing drain valve, it should be closed.
- Check the primer valve, it should be opened.
- Check any air leakage from suction hose.

#### If the engine seems to speed up and down (lost of suction)

- Make sure the suction hose is straight and does not allow any air pockets to be trapped.
- Check any air leakage in the suction or mechanical seal (between the pump casing and the engine)

#### Loss of suction head.

• Check the rubber seal in the suction hose

#### The pump is not pumping as much as it should and the revolutions of the engine are high

• Check for any obstruction in the suction hose (leaves, rocks, etc.)

# BREAK-IN PERIOD

Do not use the pump more than 1/2 throttle for the first one and half hour.

# MODELS AVAILABLE

From 2 hp to 60 hp, diesel and gas engines. Skid mounted to floating pump, ask your local dealer for more information or call us.



ACCEPT ONLY THE BEST 75 Hector St., P.O. Box 90, Pierreville (Québec) Canada JOG 1J0 Telephone: 1-800-567-2719 Fax: 1-800-434-2613 www.fire-pump.com

A CENTURY OF ENGINEERING FOR THE BRAVEST

SM-PFP-25hp-DSL-MR

# WARRANTY

CET warrants to the original purchaser that CET will, at its election, either replace or repair any part of the new equipment sold to the purchaser hereunder which has been given no abnormal use; and which has received proper maintenance; and which is determined by CET to be defective in material or workmanship; and which has, within two (2) years after delivery to the purchaser be returned at the purchaser's expense, with transportation charges prepaid, to CET factory OR which has, within two (2) years after delivery to the purchaser, been pre-approved by CET for a third-party to perform the work. All problems shall be reported to CET in writing and damaged parts shall be returned to CET.

#### **Exclusions from warranty**

1. CET incurs no liability under this warranty or otherwise for parts, accessories or components not manufactured by it, but purchased for assembly into the equipment, but CET will assign to the Purchaser whatever warranty rights are extended by the supplier of such part, accessory or component


2. CET incurs no liability under this warranty or otherwise, for equipment which has been abused, altered or improperly maintained, or for equipment which has been returned for inspection or repair more than ten (10) days after defect complained of has been or should have been discovered by the Purchaser, or Equipment which is operated after the defect has been discovered.

3. CET incurs no liability for alteration or repairs unless the Purchaser first receives CET / written consent or approval. CET will not be responsible for work or repairs made or done by others.

4. CET incurs no liability for design alterations, parts, accessories or components which are not standard but are specified by the Purchaser for incorporation into the equipment.

#### INTERPRETATION

CET shall not be liable for transportation charges either in shipment to or by it and shall not be liable for loss of use, or consequential damage of any kind in connection with the sales, alteration, repair or replacement of any equipment or part thereof. Liability under this warranty is limited to replacement or repair and in any event shall not exceed the purchase price paid. This warranty is not



# REGISTRATION

### TO BE RETURNED TO THE MANUFACTURER — FAX: 1-800-434-2613

Fire Department of :	
Address :	
_	
_	
Purchasing date :	
Serial Number :	
Dealer's Name :	

**SEND TO:** C.E.T. FIRE PUMPS MFG 75 Hector St. P.O. Box 90, Pierreville, Qc. JOG 1J0 CANADA